

Tele: 23793509

**Policy Letter No 35/2012**

Directorate General Married  
Accommodation Project (DG MAP)  
Engineer-in-Chief's Branch,  
Integrated HQ of MoD (Army)  
Kashmir House, Rajaji Marg,  
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/35/MAP  
-----  
-----  
-----

03 Aug 2012

(All PMs & DEPMCs)

**SPECIFICATIONS: KITCHEN SINK, DRAINAGE BOARD AND PLATE RACK**

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraphs are the specifications for Kitchen Sink, drainage board and Plate Rack for the future projects of MAP Phase-II & Phase-III:-

(a) **KITCHEN SINK:**

(i) **Kitchen Sink for Officer's DU's:** The Kitchen Sink should be ISI embossed (IS: 13983) single bowl kitchen sink with drainage board in glossy finish made of stainless steel grade 304 AISI (18/8) & 1 mm thick with overall size 41"x 20" and bowl size 20"x16" of 8" depth with side border as specified in IS code. The Kitchen Sink shall be connected with 40mm diameter waste coupling and PVC waste pipe of flexible type.

(ii) **Kitchen Sink for JCOs/ORs DUs:** The Kitchen Sink should be IS embossed (IS:13983) single bowl kitchen sink with drainage board in glossy finish made of stainless steel grade 304 AISI (18/8) & 1mm thick with overall size 36"x18" and bowl size 16"x14" of 8" depth and each kitchen sink shall be connected with 40mm diameter waste coupling and PVC waste pipe of flexible type.

(b) **PLATE RACK:**

(i) **OFFICERS DUs:** Plate Rack shall be of stainless steel size 900x750x250mm and thickness of sheet shall be 0.63mm of grade AISI 304 (18/8). The hooks for hanging the utensils should of high quality.

(ii) **JCOs/ORs DUs:** Plate Rack shall be of stainless steel size 750x600x250mm and thickness of steel shall be 0.63mm of grade AISI 304 (18/8). The hooks for hanging the utensils should be of high quality.

(JS Sodhi)  
Lt Col  
SO 1 (P&S)  
for DG MAP

**Internal**

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-

Tele: 23793509

**Policy Letter No 36/2012**  
Directorate General Married  
Accommodation Project (DG MAP)  
Engineer-in-Chief's Branch,  
Integrated HQ of MoD (Army)  
Kashmir House, Rajaji Marg,  
DHQ PO, New Delhi-110011

21379/Spec Ph-III/P&S/ 36/MAP  
-----  
-----  
-----

03 Aug 2012

(All PMs & DEPMCs)

**SPECIFICATIONS: WHITE/COLOUR WASHING**

1. Refer this Headquarters letter No 21378/Vendor PH-III/P&S/03/MAP dt 29 Jun 2012.
2. Given in the succeeding sub paragraph are the specifications for White/Colour washing for the future projects of MAP Phase-II & Phase-III:-
  - (a) Three Coats of white washing on newly plastered surfaces of WC, bathroom, passage of servant quarters, independent garages, all ceilings, structures like baggage room, milk booth and still area etc shall be carried out as specified. Two coats of colour wash over one coat of white wash shall be carried out in Room of servant quarters as specified in subsequent paragraphs.
  - (b) Lime used for white washing shall be freshly burnt fat lime (Class C) or magnesium lime/siliceous dolomitic lime (Class D or F), white in colour, conforming to IS-712-1984 (Specification for building limes).
  - (c) Preparation of surfaces: Refer clause 15.12 of MES Schedule Part-I.
  - (d) Preparation of whitewash: Refer clause 15.12.3 of MES Schedule Part-I.
  - (e) Preparation of colour wash: Refer clause of 15.12.4 of MES Schedule Part-I. Colours used in the preparation of the colour wash shall be first dissolved in water. Sufficient quantity of solution enough to produce the colour of required shade shall be strained through a clean coarse cloth and the filtrate mixed evenly and thoroughly to the white wash.
  - (f) Application of whitewash: Refer clause 15.12.5 of MES Schedule Part-I. Unless otherwise indicated, three coats of white wash shall be applied so that the surface presents a smooth and uniform finish through which the plaster does not show. The finished dry surface shall not show any signs of cracking and peeling and the whitewash shall not come off readily on the hand, when rubbed. For white wash on ceiling adequate quantity of zinc oxide shall be added to lime wash for achieving pure white shade.
  - (g) Whitewashing on ceiling should be done prior to that on walls.
  - (h) Application of colourwash: Refer clause 15.12.6 of MES Schedule Part-I. The colourwash shall be applied as described for white wash. For colourwash on new surfaces after the surface has been prepared, the first primary coats shall be of whitewash. The specified number of coats (minimum two) colourwash shall then be applied. The entire surface shall present a smooth and uniform finish.

(JS Sodhi)  
Lt Col  
SO 1 (P&S)  
for DG MAP

**Internal**

Team 'A'	-	for necessary action please
Team 'B'	-	-do-
Contract Section Team 'A'	-	-do-
Contract Section Team 'B'	-	-do-
Arch Section	-	-do-